



Our Ref: CR/JC

14 July 1998

Jotun Powder Coatings Ltd
Flixborough Industrial Estate
Flixborough
Scunthorpe
South Humberside
DN15 8RS

Dear Sir

WATER BYELAWS SCHEME
"ITEMS WHICH HAVE PASSED FULL TESTS OF EFFECT ON WATER QUALITY - BS 6920"

We refer to your application for the material(s) described below to be approved arising from the results of the tests of effect on water quality that have been carried out on the product(s) so described, it has been decided that there is no objection to its/their use provided the source, nature and manufacturing processes of the ingredients and products are not changed. (See notes overleaf).

COATINGS, PAINTS & LININGS - FACTORY APPLIED

5030

Valspar. D1003 Blue (94505 RD). D1003LD Cream (940260) and D1003LD (970795RD). Epoxy powder coating (FAP). Cold water applications only.

Audit Test Report: M101672

9806506


JOTUN POWDER COATINGS LTD

An entry, as above, will accordingly be included in the Water Fittings and Materials Directory, Part Two, under the section headed, "Materials which have passed full tests of effect on water quality".

Your attention is drawn to the statement overleaf. Manufacturers or applicants may only quote in their sales literature terms which are used in this letter, namely that the product as listed, having passed the tests of effect on water quality, is suitable for use in contact with potable water and that a reference to the product will be included in the Materials section, Part Two, of the Water Fittings and Materials Directory: this may be abbreviated to "Water Byelaws Scheme - Approved Product" or "WBS - Approved Product". Approval of this product does not signify the approval of its mechanical or physical properties for any use.

The Technical Committee of the Scheme reserves the right to review approval. This product automatically becomes due for audit reassessment in June 2003.

Yours faithfully


Chris Ramsey (Miss)
Materials Administrator
Water Byelaws Scheme

WIS EVALUATION & TESTING CENTRE LTD, FERN CLOSE, PEN-Y-FAN INDUSTRIAL ESTATE,
OAKDALE, GWENT, NP1 4EH, UK.
TEL: 01495 248454. FAX: 01495 249234.

WIS Evaluation & Testing Centre Ltd, Registered in England No. 2111721. Registered Office: 200 Broad Road, Highgate, London, N10 0PT, England.

